

DIMENSION A: 1" MIN., 2" MAX. (TYP. - ALL CONDUITS)
 B: 1" MIN., 2" MAX. ABOVE GROUT (TYP. ALL CONDUITS)

NOTES:

1. SEE NOTES DRAWINGS E-04, E-05, E-06, AND E-37
2. PROVIDE 3' OF SLACK IN ALL CONDUCTORS IN ACCORDANCE WITH SPECIFICATIONS. (SLACK NOT SHOWN).

APPROVED BY


Ad

DATE

3/3/92

UNDERGROUND STREETLIGHT SERVICE TYPE IA - 120V

DEPARTMENT OF PUBLIC WORKS



DRAWING NO.

E-33